IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Timbers WSD

Had the following Violations Identified During a Drinking Water Inspection

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on September 29, 2026 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Required Language	Date Correction is Required	Steps We Are Taking
Supplier has not achieved the backflow prevention annual compliance ratio.	**Uncontrolled cross connections can lead to a back pressure or siphonage event that may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.**		Two backflow prevention assembly devices were identified that did not get tested in calendar year 2025 resulting in a backflow and cross connection control rule annual testing compliance ratio that was not in compliance.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the inspection it was identified that we did not complete all monitoring/testing, were not monitoring correctly, or were monitoring at an inappropriate location. Therefore we cannot be sure of the drinking water quality during that time.

What does this mean? What should I do?

- There is nothing you need to do at this time**.** If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

The problem was resolved on **October 1, 2026 and October 29, 2026** when the supplier provided a passing test results for both backflow prevention devices. For more information, please contact **Tim Gibbons** at **suekimes@hotmail.com** or **970-734-7909**, or **Timbers Water and Sanitation District PO Box 772636 Steamboat Springs, CO 80477**.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: Timbers WSD - CO0154743
Date distributed: **11/6/2026**